

South Jersey
Water Test, LLC
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #15606

Cranberry Pines Elementary School

400 Fairview Road
Medford, NJ 08055

Results of Lead Analysis

Date & Time Sampled: 04/20/2017 07:22-07:28

Date & Time Analyzed: 04/27/2017 14:07 - 14:34


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
CRAN-DW-RM703	14.7	15.5
CRAN-SO-MEDIA	4.12	15.5

Units - ug/L = ppb


Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Milton H. Allen Elementary School

24 Allen Avenue
Medford, NJ 08055

Results of Lead Analysis

Date & Time Sampled: 04/20/2017 07:55 - 07:58

Date & Time Analyzed: 04/27/2017 13:22 - 13:48

Date & Time Analyzed: 04/28/2017 19:28

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
ALLN-CS-RM3	19.2	15.5
ALLN-CS-RM3 - Flushed	<2.00	15.5

Units - ug/L = ppb


Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Everett Haines 6th Grade Center

162 Stokes Road
Medford, NJ 08055

Results of Lead Analysis

Date & Time Sampled: 04/20/2017 07:44 - 07:47

Date & Time Analyzed: 04/27/2017 13:55 - 14:01


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
SIX-SO-MEDIA	7.30	15.5

Units - ug/L = ppb


Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Medford Memorial Middle School

55 Mill Street
Medford, NJ 08055

Results of Lead Analysis

Date & Time Sampled: 04/20/2017 07:36 - 07:40

Date & Time Analyzed: 04/27/2017 13:16 - 13:29


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
MEM-KE-KITCH	8.99	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/4/17
Date