



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Medford Township Board of Education

137 Hartford Road
Medford, NJ 08055

Results of Lead Analysis

Date & Time First Draw Sampled: 02/19/2017 08:24 - 8:30

Date & Time Analyzed: 02/23/2017 10:15 - 11:00

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
MCA-WC-01-HALL	<2.00	15.5
MCA-DW-01-KITCH	<2.00	15.5
MCA-DW-02-KITCH	<2.00	15.5
MCA-WC-02-HALL	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.
Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

3/6/17

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Medford Twp. BOE
Contact: Mr. John Gallagher
Address: 28 Brantin Rd.
 Medford, NJ 08055
Phone:
Office: (609) 953-5841 X 1507
Fax:

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P60897	MCA - FB	2/19/17	0824	D	1 x 250	HNO3*	First Draw Lead	FIELD BLANK
P60898	MCA-WC-01-HALL		0825	D	1 x 250	HNO3*	First Draw Lead	
P60899	MCA-DW-01-KITCH		0826	D	1 x 250	HNO3*	First Draw Lead	
P60900	MCA-DW-02-KITCH		0828	D	1 x 250	HNO3*	First Draw Lead	
P60901	MCA-WC-02-HALL		0830	D	1 x 250	HNO3*	First Draw Lead	
	end of samples			D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format X Standard - Lead Excel NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions Field Blank already preserved * HNO3 preserved upon receipt at laboratory	Cooler Temp °C Yes No
---	--	---	--------------------------------

Sampled by: (Print) James Ebertz (Signature) James Ebertz	Date 2/20/17	Received by: (Signature) [Signature]	Date 2/20/17	Time 1200
Relinquished by: (Signature) [Signature]	Date	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Date	Received by: (Signature)	Date	Time

CHAIN OF CUSTODY RECORD

Customer:	Medford Twp. BOE
Contact	Mr. John Gallagher
Address:	28 Branin Rd. Medford, NJ 08055
Phone:	Fax:
Office:	(609) 953-5841 X 1507

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterfest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	MCA-WC-01-HALL	2/19/17	10845	D	1 x 250	HNO3*	Flushed Lead	
	MCA-DW-01-KITCH		0827	D	1 x 250	HNO3*	Flushed Lead	
	MCA-DW-02-KITCH		0829	D	1 x 250	HNO3*	Flushed Lead	
	MCA-WC-02-HALL		0846	D	1 x 250	HNO3*	Flushed Lead	
	end of samples			D	1 x 250	HNO3*	Flushed Lead	
				D	1 x 250	HNO3*	Flushed Lead	
				D	1 x 250	HNO3*	Flushed Lead	
				D	1 x 250	HNO3*	Flushed Lead	
				D	1 x 250	HNO3*	Flushed Lead	
				D	1 x 250	HNO3*	Flushed Lead	
				D	1 x 250	HNO3*	Flushed Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard - Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Analyze Flash sample for any 1st Draw over 15.5 ppb * HNO3 preserved upon receipt at laboratory	°C Properly Preserved Yes No

Sampled by: (Print) James Eberts	Date	Time	Received by:	Date	Time
(Signature) James Eberts	2/20/17	12:00	(Signature)		
Relinquished by:	Date	Time	Received by:	Date	Time
(Signature)			(Signature)		
Relinquished by:	Date	Time	Received by:	Date	Time
(Signature)			(Signature)		