



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Maintenance Garage

26 Allen Avenue
Medford, NJ 08055

Results of Lead Analysis

Date & Time First Draw Sampled: 02/19/2017 09:06 - 09:18

Date & Time Analyzed: 02/23/2017 11:06 - 11:42

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
BUS-WC-BETRR	<2.00	15.5
BUS-SO-RESRM	<2.00	15.5
BUS-SO-TRANS	3.93	15.5
BUS-WO-BREAK	2.10	15.5
BUS-SO-SODEXO	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

3/6/17

Date

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer:	Medford Twp. BOE
Contact	Mr. John Gallagher
Address:	28 Branin Rd. Medford, NJ 08055
Phone:	Fax:
Office:	(609) 953-5841 X 1507

Lab ID#	Sample Location	Collection Date	Time	Q ad	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P60902	BUS-FB	2/19/17	0906	X		D	1 x 250	HNO3*	First Draw Lead	FIELD BLANK
P60903	BUS-WC-BETRR		0908	X		D	1 x 250	HNO3*	First Draw Lead	
P60904	BUS-SO-RESRM		0909	X		D	1 x 250	HNO3*	First Draw Lead	
P60905	BUS-SO-TRANS		0911	X		D	1 x 250	HNO3*	First Draw Lead	
P60906	BUS-WO-BREAK		0916	X		D	1 x 250	HNO3*	First Draw Lead	
P60907	BUS-SO-SODEXO		0918	X		D	1 x 250	HNO3*	First Draw Lead	
	END OF SAMPLES			X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard - Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory	°C
		Yes	No

Sampled by: (Print) James Ebertz	Received by: (Signature) [Signature]	Date 2/20/17	Date 2/20/17	Time 1200	Time 1200
Sampled by/Relinquished by: (Signature) [Signature]	Received by: (Signature)	Date	Date	Time	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time	Time

CHAIN OF CUSTODY RECORD

Customer: Medford Twp. BOE
Contact: Mr. John Gallagher
Address: 28 Branin Rd.
 Medford, NJ 08055
Phone:
Office: (609) 953-5841 X 1507
Fax:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	g/g	g/g	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	BUS-WC-BETER	2/19/17	0928	X		D	1 x 250	HNO3*	Flushed Lead	
	BUS-SO-RESEM		0910	X		D	1 x 250	HNO3*	Flushed Lead	
	BUS-SO-TRANS		0912	X		D	1 x 250	HNO3*	Flushed Lead	
	BUS-WO-BREAK		0917	X		D	1 x 250	HNO3*	Flushed Lead	
	BUS-SO-SODEXO		0919	X		D	1 x 250	HNO3*	Flushed Lead	
	END OF SAMPLES			X		D	1 x 250	HNO3*	Flushed Lead	
				X		D	1 x 250	HNO3*	Flushed Lead	
				X		D	1 x 250	HNO3*	Flushed Lead	
				X		D	1 x 250	HNO3*	Flushed Lead	
				X		D	1 x 250	HNO3*	Flushed Lead	
				X		D	1 x 250	HNO3*	Flushed Lead	
				X		D	1 x 250	HNO3*	Flushed Lead	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AAQUEOUS S=SOIL SL=SLUDGE G=GROUND WATER S=SURFACE WATER W=WASTE WATER

Turnaround Time X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format X Standard - Lead Excel NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions Analyze flush sample for any 1st draw over 15.5 ppb * HNO3 preserved upon receipt at laboratory	Cooler Temp °C Properly Preserved Yes No
--	---	---	--

Sampled by: (Print) James Eberts	Received by: (Signature) [Signature]	Date 2/20/17	Time 12:00
Sampled by/Relinquished by: (Signature) [Signature]	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time